MATERIAL SAFETY DATA SHEET STEEL PRODUCTS

	CODE NO.:	na
ORIGINAL ISSUE DATE:	4/11/07	REVISED:

I. IDENTIFIC	ΔΤΙΩΝ		INFORMATION AND EMERGENCY TELEPHONE					
I. IDENTIFICATION PRODUCT NAME: Galvanized Carbon Steel; Pipe, Tube &			NUMBERS (708) 339-1610					
Open profile shap								
COMMON NAME (S): EMT, COLORED EMT, IMC, RIGID, FENCE, MECHANICAL, ANGLE, CHANNEL			MANUFACTURER: Allied Tube & Conduit Corp 16100 South Lathrop Avenue Harvey, IL 60426					
II. INGREDIENTS AND RECOMMENDED OCCUPATIONAL EXPOSURE LIMITS								
Note: Steel Products u	nder normal con	ditions do not present an inhalation, ingestion, or						
BASE METAL, ALLOYING ELEMENTS AND METALLIC % WEIGHT		EXPOSUR During operations (such as welding, burning, c	E LIMITS* r cutting) where dust or fumes are generated.					
COATINGS		OSHA PEL	ACGIH TLV (1992-1993)					
Base Metal: Iron CAS 7439-89-6	95.7 – 98.3	10 mg/M ³ for total particulate as iron oxide – total dust 5 mg/M ³ for total particulate-respirable fraction	5 mg/M ³ for iron oxide fumes					
Alloying Elements: Carbon CAS 7440-44-0	0.25 max	10 mg/M ³ for total dust (pnor) ^d 5mg/M ³ for respirable fraction (pnor) ^d	10 mg/M ³ for total dust (pnos) ^e 3 mg/M ³ for respirable fraction (pnos) ^e					
*Manganese CAS 7439-96-5	0.95 max	(c) 5 mg/M ³ – compounds (b) 3 mg/M ³ – fume 1 mg/M ³ - fume	5 mg/M ³ – dust & compounds 1 mg/M ³ – fume (b) 3 mg/M ³ - fume					
*Phosphorus CAS 8049-19-2	0.035 max	10 mg/M ³ for total dust (pnor) ^d 5mg/M ³ for respirable fraction (pnor) ^d	10 mg/M ³ for total dust (pnos) ^e 3 mg/M ³ for respirable fraction (pnos) ^e					
Sulfur CAS 7704-21-3	0.035 max	5 mg/M ³ as sulfur dioxide (b) 10 mg/M ³ – as sulfur dioxide	5.2 mg/M³ as sulfur dioxide (b) 13 mg/M³ – as sulfur dioxide					
Metallic Coating: *Zinc CAS NO 7440-66-6 Zinc Dust or Fume	0.50 - 3.00	5 mg/M ³ as zinc oxide fume (b) 10 mg/m ³ – zinc oxide fume 10 mg/M ³ - zinc oxide dust 5 mg/M ³ - zinc oxide respirable fraction	10 mg/M ³ - zinc oxide total dust 5 mg/M ³ - zinc oxide fume (b) 10 mg/M ³ – zinc oxide fume					
*Aluminum CAS NO 7429-90-5 Aluminum Dust or Fume	<0.10	15 mg/M ³ – metal dust 5 mg/M ³ – respirable fraction	10 mg/M ³ – dust 5 mg/M ³ – welding fumes					
*Chromium CAS 7440-47-3	<0.0005	1 mg/M ³ as metal	0.5 mg/M ³ as metal or Cr III compounds					
Polymeric OD Coatings	<0.50	n/a	n/a					
Polymeric ID Coatings	0.10 max	n/a	n/a					
 Subject to Section (d) Particulates not of (e) Particulates not of 	limit" which is on EPCRA 313 therwise regula therwise speci	not to be exceeded at any time.	specific name illica or asbestos					
III. PHYSICA	L DATA							
Melting Point Base Material: 2750		Metallic Coating: 800°-900° F	Appearance & Bright Metallic Odor: No Odor					
IV. FIRE AND EXPLOSION DATA Steel Products in the Solid State present no fire or explosion hazard.								
V. REACTIV	ITY DATA		to liberate hydrogen. At temperatures of					
Stable under normal conditions of use, storage, and transport. Will react with strong acid to liberate hydrogen. At temperatures above								

MATERIAL SAFETY DATA SHEET STEEL PRODUCTS

the melting point of the coating, galvanized pipe may liberate zinc fumes, carbon monoxide, and oxides of nitrogen.

VI. HEALTH HAZARD DATA

Note: Steel products under normal conditions do not present an inhalation, ingestion, or contact health hazard. However, operations such as burning, welding, sawing, brazing, grinding, and possibly machining, etc, which result in elevating the temperature of the product to or above its melting point or result in the generation of airborne particulates, may present health hazards.

EFFECTS OF OVEREXPOSURE:

Major Exposure Hazard

INHALATION	SKIN CONTACT	EYE CONTACT	INGESTION
X			·

Chronic inhalation of high concentrations of iron oxide fumes or dusts may lead to a benign pneumoconiosis (siderosis). Inhalation of high concentrations of ferric oxide may possibly enhance the risk of lung cancer development in workers exposed to pulmonary carcinogens.

The inhalation of high concentrations of freshly formed oxide fumes and dusts of Manganese, Copper, Lead and/or Zinc in the respirable particle size range can cause an influenza-like illness termed metal fume fever. Typical symptoms last 12 to 48 hours and are characterized by metallic taste in the mouth, dryness and irritation of the throat, followed by weakness, muscle pain, and chills. No long term effects of metal fume fever have been noted.

EMERGENCY AND FIRST AID PROCEDURES

For overexposure to airborne fumes and particulates, remove exposed person to fresh air. If breathing is difficult or has stopped, administer artificial respiration or oxygen as indicated. Seek medical attention promptly.

Treat metal fume fever by bed rest and administer a pain and fever reducing medication.

VII. SPILL OR LEAK PROCEDURES

Not applicable to steel in the solid state.

VIII. SPECIAL PROTECTION INFORMATION

RESPIRATORY: For welding or burning – NIOSH/MSHA approved dust and fume respirators should be used to avoid excessive inhalation of particulates. Appropriate respirator selection depends on the magnitude of exposure.

SKIN: Protective gloves should be worn as required for welding, burning, or handling operations.

EYE: Use safety glasses or goggles as required for welding, burning or handling operations.

VENTILATION: Local exhaust ventilation should be provided when sawing, grinding or machining to prevent excessive dust or fume exposure. During welding, burning or brazing please follow the ANSI Standard Z49.1 "Safety in Welding and Cutting".

OTHER PROTECTIVE EQUIPMENT: Depending upon the conditions of use and specific work situations, additional protective equipment and/or clothing may be required to control exposures.

IX. SPECIAL PRECAUTIONS

PRECAUTIONS TO BE TAKEN IN HANDLING AND STORAGE: Operations with the potential for generating high concentrations of airborne particulates should be evaluated and controlled as necessary. Avoid breathing metal fumes and/or dusts.

OTHER COMMENTS:

MEDICAL CONDITIONS AGGRAVATED BY EXPOSURE: Individuals with chronic respiratory disorders (ie asthma, chronic bronchitis, emphysema, etc) may be adversely affected by any fume or airborne particulate matter exposure.

THIS INFORMATION IS TAKEN FROM SOURCES OR BASED UPON DATA BELIEVED TO BE RELIABLE; HOWEVER ALLIED TUBE & CONDUIT CORPORATION MAKES NO WARRANTY AS TO THE ABSOLUTE CORRECTNESS OR SUFFICIENCY OF ANY OF THE FOREGOING OR THAT ADDITIONAL OR OTHER MEASURES MAY NOT BE REQUIRED UNDER PARTICULAR CONDITIONS.